



Booster Heat Pump



Annex 46 Meeting, February 11, 2016

Netherlands Enterprise Agency / Entry Technology Support BV

Schematic




Drivers Booster Heat Pump

Drivers:


1. On the spot DHW preparation, reduction of distribution losses
2. 2nd law optimisation (dedicated heat pump operation, only for high (DHW) discharge temperatures)
3. Reduction of supply temperature, increased performance of source generator efficiency (e.g. Solar)
4. DHW preparation e.g. by space cooling



Reference: Alternatives Hot Water preparation

DANFOSS, LOW TEMPERATURE DISTRICT HEATING CONSUMER UNIT WITH MICRO HEAT PUMP FOR DOMESTIC HOT WATER PREPARATION, E.Zvingilaite et al.,



Annual socioeconomic costs for DHW heating





Energy Performance Standard ?

Key parameter: Equivalent Generation Efficiency for Hot Water, including district energy infrastructure (dei):


$$\eta_{W;gen;equiv;tot}$$

$$\eta_{W;gen;equiv} = \frac{\text{Total heat supplied @ Water heating system}}{\text{All primary energy needed (electricity + heat, incl loss)}}$$

$$\eta_{W;gen;equiv} = \frac{\sum_{zi} \sum_{mi} Q_{W,dis,nren}}{E_{W;el} \times f_{P;del;el} + E_{W;dh} \times f_{P;del;dh} + E_{W;aux} \times f_{P;del;el}}$$

Input:

1. Measured performance of Booster heat pump




2. Temperature level and generator efficiency of district heating system, including losses
3. Hot water demand
4. Optional: Cooling load of the building

Spreadsheet

Residential Booster Heat Pump with Thermal Energy Supply from District Heating and Building Cooling											
			Month	JAN	MAR	JUN	JUL	AUG	SEP	DEC	
Usefull area	Ag:zi	150	Temperature [C]	2,6	13,3	16	17,4	17,4	14,6	4	sums
Building units	NW:zi	1	Mseconds	2,6784	2,6784	2,592	2,6784	2,6784	2,592	2,6784	31,536
			Mseconds	2,6784	2,6784	2,592	2,6784	2,6784	2,592	2,6784	31,536
Total DHW Heat Load (W)	QW;nd		[MJ/month]	727,45	727,45	703,99	727,45	727,45	703,99	727,45	
Emitter efficiency	ηW;em	1	[-]								
Distribution system efficiency	ηW;dis	0,742	[-]								
Total DHW Heat Load (W)	QW;dis;ren		[MJ/month]	980,40	980,40	948,77	980,40	980,40	948,77	980,40	1,15E+04
DH-supply Temperature	tdh;supp		[°C]	27,44	21,02	20,00	20,00	20,00	20,24	26,60	
COP Booster (incl ls, @ 14000 MJ)	ηW;gen		[-]	3,41	3,09	3,04	3,04	3,04	3,05	3,37	
COP Booster (excl ls, @ 14000 MJ)	ηW;gen			3,86	3,45	3,39	3,39	3,39	3,40	3,80	
COP Booster (incl ls, @ actual MJ)	ηW;gen			3,33	3,02	2,97	2,97	2,97	2,99	3,29	
Heat Load Booster (BHP thermal energy need)				686,01	656,17	629,85	650,85	650,85	631,08	682,43	7,84E+03
Summer Comfor Cooling ηC;gen;SI QC;nd;zi,mj			[MJ/month]	0,00	4,00	341,00	796,00	622,00	8,00	0,00	1,77E+03
Energy W (drawn from dh)	QW;dis;ren		[MJ]	686,01	652,17	288,85	0,00	28,85	623,08	682,43	6,21E+03
EL Booster	EW;gen;el		[Mje]	294,39	324,23	318,92	329,55	329,55	317,69	297,97	3,71E+03
Specific power circulation pump	PC;aux;ngen;spec	2	W/m2								
On-time circulation pump	TC;on;mi		[Ms]	0,00	0,00	0,23	0,43	0,41	0,01	0,00	1,08E+00
Auxiliary energy circulation pump:	WC;aux;ngen;mi			0,00	0,01	0,45	0,87	0,83	0,01	0,00	2,17E+00
Remaining Cooling load	QC;nd;zi,mj*		[MJ/month]	0,00	0,00	0,00	145,15	0,00	0,00	0,00	1,45E+02
EMG Equiv. Gen Eff. (H+W)	ηH+W;gen;equiv;tot	150%									
Etot;pr;el		9,49E+03	[MJ/an]								
Etot;pr;q		4,14E+03	[MJ/an]								
Equiv. Gen Eff. (H+W) BHP	ηW;gen;equiv;tot	84,67%									
Equiv. Gen Eff. Cooling	ηC;gen;equiv	3660,28%									


Testresults	
QW;dis;ren	14000
T [C]	
24	3,24
40	4,04
EW;el;stat	15

Results



Booster heat pump efficiency, with and without building cooling, depending on district heating generation efficiency, for $A_g=150 \text{ m}^2$, $\text{COP}=4,04$ @ 14000 MJ.

Optional bonus (Free cooling):



$$\eta_{C;gen;SC} = \frac{Q_{C;nd}}{E_{SC;el*}} = \frac{Q_{C;nd}}{Q_{C;nd*}} \eta_{C;gen;SC,default}$$

Conclusions:

- 1) Calculation procedure Booster heat Pump established & effectively standardised
- 2) Effect on Energy Performance identified
- 3) Including summer cooling
- 4) Booster Heat Pumps now on the market

Closure

With acknowledgment to:



Thanks for your attention
J. van Berkel,
Entry Technology Support BV
entry@xs4all.nl